

**GREATER VICTORIA
DIVISION 15 SUB-TRADE
BID DEPOSITORY**

#223, 3989 Henning Drive, Burnaby, BC V5C 6N5
ph: 1-800-663-8473 fax: 604-205-5075

File: 42504

July 21, 2010

MEMO

TO: All Bid Depository Users – Clarification # 2

FROM: Jane Andrew (for Russ Hepworth Chair)

RE: VP2010-002 CFB Base Fire Hall & Emergency Response Centre
Clarification Request Sent In By Playsted Sheet Metal

“Please clarify who installs the following:

- 1) The Muffler or silencer off the generator is provided by Div26 and installed by the mechanical contractor or sheet metal contractor?*
- 2) The sheet metal contractor would supply and install the chimney off the muffler if acceptable.”*

In response to enquiries on the above project the Bid Depository Management Committee has decided that:

The Mechanical Contractor normally installs the Gen set exhaust system, the Mechanical Contractor install the silencer (muffler) as shown and the ventilation contractor supply the chimney (exhaust pipe) from the silencers to termination as shown/noted.